

SECTION 16700: SPECIAL SYSTEMS

PART 1 - GENERAL

1.1 SCOPE:

Work of this Section shall be in accordance with the intent of the Contract Documents and shall include the following principal items:

Telephone Conduit System

1.2 REFERENCED STANDARDS:

NFPA 70 - National Electrical Code

PART 2 - PRODUCTS

NOT APPLICABLE

PART 3 - EXECUTION

3.1 TELEPHONE CONDUIT SYSTEM:

Provide a complete telephone conduit system including plywood terminal boards, conduit runouts to each phone outlet and other items as indicated. Contractor shall leave #14 pull wire in each conduit to facilitate pulling telephone cable.

END OF SECTION